



MOVE YOUR ENVIRONMENT FORWARD

2019 ANNUAL REPORT

Waterbury, CT

Small Municipal Separate Storm Sewer Systems (MS4)

Prepared For:

City of Waterbury
Department of Public Works
Waterbury, CT

Prepared By:

HRP Associates, Inc.
197 Scott Swamp Road
Farmington, CT 06032

HRP #: WAT4044.EE

Issued On: February 5, 2020

MS4 General Permit
City of Waterbury, CT, 2019 Annual Report
Existing MS4 Permittee
Permit Number GSM000094
January 1, 2019 – December 31, 2019

This report documents the City of Waterbury’s efforts to comply with the conditions of the MS4 General Permit to the maximum extent practicable (MEP) from January 1, 2019 to December 31, 2019.

Part I: Summary of Minimum Control Measure Activities

1. Public Education and Outreach (Section 6 (a)(1) / page 19)

1.1 BMP Summary

BMP	Status	Activities in current reporting period (if needed, more space available after this table)	Measurable goal	Department / Person Responsible	Due	Date completed or projected completion date	Additional details
1-1 Implement public education and outreach	Ongoing	EPA Stormwater education materials located on City website, Educational Program at Girls, Inc., Stormwater information is provided on Social Media, Naugatuck River Brigade	Provide Education May include: workshops, literature distribution and/or signage posting	Public Works or Dept. of Education / City Engineer / Mayor’s office	Ongoing	Implemented by July 1 2018	Continue with current education efforts
1-2 Address education/ outreach for pollutants of concern*	Ongoing	The City distributes info on common sources of phosphorus, nitrogen and bacteria pollution and how to	Distribute literature, post signage	Public Works or Dept. of Education / City Engineer	Ongoing	Implemented by July 1, 2018	Topics to address bacteria may include: septic systems, sanitary cross connections, pet waste, and waterfowl. Continuing with current efforts.

		prevent/reduce the amount reaching the MS4.					
1-3 Make GIS information available	Ongoing	The City's storm system mapping can be found on the City's Live GIS mapping site.	Public GIS access	PW and IT/ City Engineer	N/A	Ongoing	http://gis.waterburyct.org/GIS/GIS_MappingSites.asp
1-4 Storm Drain inlets labelled	In progress	The City has a Catch basin standard frame that states "Dump No Waste. Drains to Waterways." Contractors are required to use this frame within the City Right Of Way.	Catch basin standard frame	PW/City Engineer	N/A	Ongoing use with new Developer projects and City projects (when available)	Continue with current efforts

1.2 Describe any Public Education and Outreach activities planned for the next year, if applicable.

The City continues to support events for World Water Day in March, 2020, Earth Day in April, 2020 and World Oceans Day in June, 2020. "Naugatuck River Brigade" will participate in Naugatuck River clean-up day efforts.

1.3 Details of activities implemented to educate the community on stormwater

Program Element/Activity	Audience (and number of people reached)	Topic(s) covered	Pollutant of Concern addressed (if applicable)	Responsible dept. or partner org.
Information on Stormwater for Citizen education can be found on the City's website at: http://www.waterburyct.org/content/9569/9605/9632/10197/default.aspx	City-wide (residents)	Stormwater	N/A	Public Works or Information Tech (IT)/ City Civil Engineer
Pet Waste Stations and signs have been posted at many City Parks in the past. These signs are maintained and replaced as needed.	City-wide (residents)	Pet Waste	E-coli (bacteria)	Public Works
Women of Water Program at Girls, Inc., August 2018	Students (approx. 80)	Impact of litter on storm drains and	N/A	Public Works

		waterways		
Social Media (Facebook and Twitter) was used periodically	Broad Audience	Litter, stormdrains, river clean-up	N/A	Public Works
Naugatuck River Brigade was formed with 13 high school students (seasonal). Removed litter and debris from the Naugatuck River. June-August 2019	Broad Audience, Students	Impacts of litter on rivers and the ecosystem	E-coli (bacteria)	Mayor's office, Police Activity League

2. Public Involvement/Participation (Section 6(a)(2) / page 21)

2.1 BMP Summary

BMP	Status	Activities in current reporting period	Measurable goal	Department / Person Responsible	Due	Date completed or projected completion date	Additional details
2-1 Continue availability of Final Stormwater Management Plan to the public	Completed	Notice of Plan Availability on website posted on City website January 28, 2019.	Plan posted on City website	Public Works/ City Engineer	Ongoing	Posted on City website on 4/3/17	Plan located here: http://www.waterburyct.org/content/9569/9605/9632/10197/default.aspx Notice of Plan Availability on website posted on City website January 30, 2020. https://www.waterburyct.org/news/?FeedID=3434
2-2 Comply with public notice requirements for Annual Reports	Ongoing	2018 Annual Report Notice of Availability posted on City website January 28, 2019. DRAFT 2018 Report posted on website on February 8, 2019 FINAL 2018 Report currently posted on website	Publish public notice, Report posted on City website	Public Works/ City Engineer	Feb 15, 2019	Notice of Availability: January 28, 2019 Report posted on website: February 8, 2019	2019 Annual Report Notice of Availability posted on City website January 30, 2020. https://www.waterburyct.org/news/?FeedID=3434 DRAFT 2019 Report posted on website on February 7, 2020 All reports can be found: http://www.waterburyct.org/content/9569/9605/9632/10197/default.aspx
2-3 Annual "Clean-up" Days along waterbodies	Ongoing	Earth Day was held on May 4, 2019.	Holding event	Public Works/Local Volunteers & Citizens	Annually		Earth Day and individual neighborhood clean-ups performed with DPW support

Extra space for describing above BMP activities, if needed:

BMP	

2.2 Describe any Public Involvement/Participation activities planned for the next year, if applicable.

The City continues to support events for World Water Day in March, 2020, Earth Day in April, 2020 and World Oceans Day in June, 2020. "Naugatuck River Brigade" will participate in Naugatuck River clean-up day efforts.

2.3 Public Involvement/Participation reporting metrics

Metrics	Implemented	Date	Posted
Availability of the Stormwater Management Plan to public	Y	3/29/17 in newspaper, 4/3/17 on website. Plan has been posted on website since 4/3/17. 2018 Notice of Plan Availability posted on City website January 28, 2019. Most recent notice of Plan Availability on website posted on City website January 30, 2020.	http://www.waterburyct.org/content/9569/9605/9632/10197/default.aspx https://www.waterburyct.org/news/?FeedID=3434
Availability of Annual Report announced to public	Y	2017 Annual Report Newspaper Notice was published on 2/15/2018. The 2018 Annual Report Notice of Availability posted on City website January 28, 2019. The 2019 Annual Report Notice of Availability posted on City website January 30, 2020	https://www.waterburyct.org/news/?FeedID=3434

3. Illicit Discharge Detection and Elimination (Section 6(a)(3) and Appendix B / page 22)

3.1 BMP Summary

BMP	Status	Activities in current reporting period	Measurable goal	Department / Person Responsible	Due	Date completed or projected completion date	Additional details
3-1 Develop written IDDE program	Completed	Plan revised February 13, 2019	Develop written plan of IDDE program	Public works/ City Engineer	Jul 1, 2018	Original completed June 29, 2018 Revised February 2019	http://www.waterburyct.org/content/9569/9605/9632/10197/default.aspx
3-2 Develop list and maps of all MS4 stormwater outfalls in priority areas	In progress	Its estimated that greater than 90% of outfalls are in the inventory and mapped	Completed list and map	Public Works/ City Engineer	July 1, 2019	Goal to be 100% by July 1, 2020, however, revisions will be on-going.	Some outfalls need additional information added to the inventory which will be collected during dry weather screening. Other outfalls need to be reclassified/relabelled. Revisions currently being made. Interconnection points still need to be mapped
3-3 Implement citizen reporting program	Completed	The Citizens Service Center website allows the public to search for info and submit service requests		Public Works/Mayor's office/IT	Ongoing	Completed prior to the new MS4 permit	Citizen's Service Center webpage: http://www.waterburyct.org/311 / Service requests can be submitted at this website. Smartphone Application: iReportWTBY can also be used to file complaints and concerns
3-4 Establish legal authority to prohibit illicit discharges	Completed	None	Establish the legal authority	Public Works/ Corporation Counsel	Jul 1, 2018	August 20, 2018	The Ordinance and legal notice can be found in the IDDE Plan on the City's website. Confirmation of the IDDE Ordinance codification is pending.
3-5 Develop record keeping system for IDDE tracking	Completed	The past 8 years of SSOs have been summarized on the inventory spreadsheet provided in the IDDE plan, and are included in this	Spreadsheet	Public Works/ City Engineer	Jul 1, 2017	January 2018	

		report. The City is using a similar spreadsheet for other IDDE tracking, in Excel format.					
3-6 Address IDDE in areas with pollutants of concern	In Progress	IDDE will be addressed City-wide	IDDE Program	Public Works/ City Engineer	Not specified	Ongoing	This BMP will be conducted in conjunction with IDDE Screening, Sampling and Investigation
3-7 Use of EpiCollect5 Mobile Phone Application for data collection in the field	Ongoing	HRP staff used the App. while conducting Dry Weather Screening/Sampling	To have data from all outfalls in one database system	Consultant/ City Engineer	-	Ongoing	

Extra space for describing above BMP activities, if needed:

BMP	

3.2 Describe any IDDE activities planned for the next year, if applicable.

The written IDDE program will be updated as needed throughout the permit term.

Maintain master IDDE tracking spreadsheet and ensure all employees involved in IDDE program understand the logging process.

Dry weather screening and sampling will continue. Once completed, catchment investigation will begin.

3.3 List of citizen reports of suspected illicit discharges received during this reporting period.

Date of Report	Location / suspected source	Response taken
None reported		

DRAFT

3.4 Provide a record of illicit discharges occurring during the reporting period and SSOs occurring July 2012 through end of reporting period using the following table.

Location (Lat long/ street crossing /address and receiving water)	Date and duration of occurrence	Discharge to MS4 or surface water	Estimated volume discharged	Known or suspected cause / Responsible party	Corrective measures planned and completed (include dates)	Sampling data (if applicable)
The City reported the following SSOs:						
35 Sharon Rd	12/15/2012; 5:30 pm – 7:30 pm	Mad River	2,000 – 3,000 gal	Sewer Main	Added to LTMP; Jetted line & vacuumed debris Add to LTMP	
605 Woodtick Rd	1/05/2015; 3:41 pm – 4:15 pm	N/A	NOT Known homeowner said minor	Raw Sewage	Added this section of Sanitary line to LTMP; Removed sticks, rags & other debris from MH#132	
Woodtick & Frost Rd	1/19/2015; 1:42 pm – 3:00 pm	N/A	Not determined. Homeowner would not let WPC worker into house for inspection	Blockage	Added to LTMP; Removed grease blockage	
Piping Rock Pump Station	2/6/2015; 10:00 am – 10:20 am	N/A	1,500 gal	Electrical Equip. Failure	Troubleshoot electric control panel; Vacuum Truck	
417 Pearl Lake Rd	3/26/2015; 12:30 pm – 12:40 pm	N/A	10 gal	Raw Sewage	Added this area to Long Term Cleaning Plan; Cleaned main line/homeowner will mop & clean garbage floor	
Overlook Ave ROW	3/31/2015; 12:45 pm – 2:15 pm	Steele Brook	2,000 gal	Blockage	Added to Long Term Cleaning Plan; Vacuumed & raked, limed waste material	
800' West of Bunker Hill Rd	5/6/2015; 12:30 pm – 4:30 pm	Trumpet Brook	2,000 gal	Broken pipe, misaligned Manhole & sewer line	Scheduled to repair misaligned manhole & sewer line; Raked & pick up debris & paper products	

Location (Lat long/ street crossing /address and receiving water)	Date and duration of occurrence	Discharge to MS4 or surface water	Estimated volume discharged	Known or suspected cause / Responsible party	Corrective measures planned and completed (include dates)	Sampling data (if applicable)
800' West of Bunker Hill Rd	5/13/2015; 2:00 pm – 4:30 pm	Trumpet Brook	2,000 - 3,000 gal	Blockage	Repaired misaligned manhole & sewer line; Raked & picked up debris & paper products	
95 Schraffs Drive	1/12/2016; 12:45 pm – 2:00 pm	N/A	800-1,000 gal	Raw Sewage	Jetted line; Owner to call contractor	
62 Hewlett St	1/21/2016; 3:35 pm – 4:00 pm	N/A	Not determined. Homeowner would not allow WPC into basement	Raw Sewage	Added this area to City's LTMP; Jetted sanitary line on Eculid Ave, MH #59 to 61- there was not any waste on ground	
25 Branch St	2/23/2016; 11:00 am – 12:15 pm	N/A	About 50 gal	Blockage	Added another cleaning day to current LTMP; Cleaned 600 ft of main sanitary line	
Harper Ave. R.O.W.	6/16/2016; 8:00 am – 9:30 am	N/A	1,500 gal	Vandals	Adding new locking MH cover; Removed debris from MH, Jetted line- vacuumed and removed paper products	
497 Plank Rd	10/10/2016; 10:50 am – 1:05 pm	Surface Water	5,000 gal	Blockage - 1-84 construction crew broke a City MH while working in the Plank Rd area	State Contractor Repaired Manhole; Removed stones & bricks from MH	
282 Scott Rd	2/6/2017; 10:26 am – 8:33 pm	N/A	51-500 gal	Roots	This area added to the LTMP	
76 Piping Rock Dr.	4/4/2017; 8:57 am – 9:52 am	N/A	51-500 gal	Blockage	Removed piece of pipe from manhole. Cleaned and limed area	

Location (Lat long/ street crossing /address and receiving water)	Date and duration of occurrence	Discharge to MS4 or surface water	Estimated volume discharged	Known or suspected cause / Responsible party	Corrective measures planned and completed (include dates)	Sampling data (if applicable)
Treatment Plant 210 Municipal Rd	4/16/2017; 10:35 pm – 11:10 pm	Naugatuck River	0.58 MG	Electrical Equip. Failure	Primary Pump Station Testing was completed on 5/15 by SNET; Debris around catch basin near the septage receiving area was removed manually using 5 gallon pails	
40 Old Colony Drive	5/7/2017; 5:07 am – 7:30 am	N/A	0-50 gal	Raw Sewage- Excessive Flows storm event	Add to LTMP & Corrective Action Plan; Cleaned 650 ft.	
62 Harper Ave	6/29/2017; 8:30 am – 10:37 am	N/A	51-500 gal	Raw Sewage/ sewer line blockage	Jetted and cleaned line from MH #63A to 64A; Cleaned and limed area	
831 Woodtick Rd	8/20/2017; 10:15 am – 10:50 am	N/A	51-500 gal	Sewer Line Blockage	This area added to the LTMP; Cleaned 1000' of the sanitary line	
5 Ward St	10/31/2017; 7:48 pm – 9:15 pm	N/A	51-500 gal	Blockage**	Added to LTMP; Removed grease blockage	
89 Clowes Terrace	1/12/2018; 4:15 pm – 5:28 pm	N/A	1-50 gal	Blockage**	Added to LTMP; Removed grease blockage	
Cornelius Ave	4/8/2018; 3:20 pm - 5:00 pm	N/A	1-50 gal	Blockage	Added to LTMP; Removed roots and debris	
3396 East Main Street*	6/4/2018 5:20 pm – 5:23 pm	N/A	Unknown	Unknown	N/A	
151 Sharon Rd	6/8/2018; 1:00 pm – 1:45 pm	Mad River	501 - 1,000 gal	Blockage	Added to LTMP; Removed grease and sand blockage	
611 Bunker Hill Ave	6/19/2018; 9:29 am – 11:01 am	Trumpet Brook	5,001 – 20,000 gal	Blockage in misaligned sanitary sewer line due to soil erosion in brook	Contractor replaced misaligned sewer lines and encased sewer lines in concrete; Raked & picked-up debris, lime waste material	

Location (Lat long/ street crossing /address and receiving water)	Date and duration of occurrence	Discharge to MS4 or surface water	Estimated volume discharged	Known or suspected cause / Responsible party	Corrective measures planned and completed (include dates)	Sampling data (if applicable)
15 Pritchard Rd	7/3/2018; 1:00 pm – 3:00 pm	N/A	1-50 gal	Blockage	Added to LTMP	
509 Willow St	8/2/2018; 5:15 pm – 7:00 pm	N/A	51 – 500 gal	Blockage**	Added to LTMP	
Lorraine St ROW	11/26/2018; 11:30 am – 1:30 pm	N/A	501 – 1,000 gal	Raw Sewage	Added to LTMP; Cleaned 400 feet of sanitary sewer line	
133 Maybrook Rd	12/21/2018; 10:15 am – 12:45 pm	Welton Brook	2,500 gal	Heavy Rain 1"-2" per hour	Review pump station capacity; Maintained with Vacuum tank truck	
52 Terrell Rd	12/21/2018; 11:40 am – 1:42 pm	N/A	300 – 400 gal	Heavy Rain 1"-2" per hour	Review pump station capacity; Maintained with Vacuum tank truck	
Colonial Ave	12/24/2018; 11:00 am – 12:30 pm	N/A	250 gal	Pump Station force main failure	Monitor pump station operations on SCADA; Maintained with Vacuum tank truck	
190 Horseshoe Drive	1/2/2019; 8:00 pm – 9:30 pm	N/A	10-20 gal	Blockage / debris**	Removed debris; jetted & cleaned sanitary main line; added to LTMP	
133 Maybrook Rd	1/24/2019; 12:50 pm – 1:15 pm	Welton Brook	50 gal	Hydraulic***	Review pump station capacity; Maintained with Vacuum tank truck	
133 Maybrook Rd	1/24/2019; 12:30 pm – 8:00 pm	N/A	1000-5000 gal; change in conveyance	Hydraulic***	Review pump station capacity; Maintained with Vacuum tank truck; change of conveyance	
52 Terrell Road	1/24/2019; 2:30 am – 4:00 pm	N/A	1000-5000 gal; change in conveyance	Hydraulic***	Review pump station capacity; Maintained with Vacuum tank truck; change of conveyance	
62 Harpers Avenue	2/27/2019; 2:35 pm – 3:50 pm	N/A	1000-5000 gallons	Blockage / Debris/rags+	Jetted & cleaned sanitary sewer line to remove blockage; spread lime; increase number of times to clean per year	

Location (Lat long/ street crossing /address and receiving water)	Date and duration of occurrence	Discharge to MS4 or surface water	Estimated volume discharged	Known or suspected cause / Responsible party	Corrective measures planned and completed (include dates)	Sampling data (if applicable)
29 Temple Street	3/24/2019; 7:25 pm – 9:30 pm	N/A	350-400 gal	Blockage / roots**	Jetted line & cut roots; added to LTMP	
341 Willow Street	4/30/2019; 4:00 pm – 4:25 pm	N/A	1-50 gal	Blockage / broken sewer	Vacuumed curb box and cleaned sidewalk area; notified Health Dept.; added to LTMP	
62 Harpers Avenue	6/11/2019; 3:05 pm – 4:55 pm	N/A	1000-5000 gallons	Blockage / Debris/rags+	Jetted & cleaned sanitary sewer line to remove blockage; spread lime; added to LTMP	
135 Industry Lane	6/24/2019; 12:00 pm – 1:30 pm	N/A	1000 gal	Blockage / Debris/rags**	Jetted private line to release blockage; notified Health Dept.	
62 Harpers Avenue	8/29/2019; 1:00 pm – 3:23 pm	N/A	400-500 gallons	Blockage / Debris/rags+	Jetted & cleaned sanitary sewer line to remove blockage; spread lime; on LTMP and inspect monthly	
3429 East Main Street	11/18/2019; 7:30 am – 10:30 pm	N/A	5000-20000 gallons	Blockage / unable to Identify++	Jacobs assisted Education Dept. w/ jetter to clear blockage; instructed Educ. Dept. to hire contractor to clean area & maintain sewer line	
38 Birch Street	12/19/2019; 10:10 pm – 11:25 pm	N/A	50-500 gal	Sewer backup / unable to identify**	Jetted sewer line to clear blockage; CCTV sewer line to ensure line integrity	

****This was reported as a bypass, however, WPC was not provided access to the basement by the property owner, and therefore could not verify that there was a bypass, the volume of it, or the cause of it. If the cause of a Bypass is not immediately clear, it may take time to identify the cause of the backup. As these cases can sometimes become legal matters and may end up in formal court proceedings and/or arbitration; having to formally commit to a cause before completing the investigation and determining the true cause could potentially undermine these proceedings.***

*****Initial appearance is that the cause was due to grease, debris and/or roots, however, further investigation is needed to confirm the cause of the bypass. If the cause of a Bypass is not immediately clear, it may take time to identify the cause of the backup. As these cases can sometimes become legal matters and may end up in formal court proceedings and/or arbitration; having to formally commit to a cause before completing the investigation and determining the true cause could potentially undermine those proceedings.***

*****The cause was due to heavy rain of 1"-2" per hour, two pumps at each pump station are capable of pumping 300 gallons per minute, but were not able to keep up with high flow. During the heavy rain in event in January 24, 2019 the sewer flow was maintained with vacuum trucks and there was a change in conveyance.**

+The cause was due to debris and rags which are most likely from unauthorized discharges from nearby Housing Authority Apartments, Housing Authority personnel are to be notified and they are to provide notification to the tenants of items that should not be flushed down the sewers.

++The private sanitary sewer and manhole services the Crosby High School and Wallace Middle School complexes, Education Department personnel were instructed to clean and maintained the private sewer system.

3.5 Briefly describe the method used to track illicit discharge reports, responses to those reports, and who was responsible for tracking this information.

Reports filed through the website or Smartphone Application are entered into the IDDE tracking spreadsheet by one of the City’s Civil Engineers.

3.6 Provide a summary of actions taken to address septic failures using the table below.

Location and nature of structure with failing septic systems	Actions taken to respond to and address the failures	Impacted waterbody or watershed, if known
Single family residence located at 1121 Chase Parkway	System fixed to City of Waterbury Department of Public Health code	Presumed to be contained on the property
Single family residence located at 1149 Pearl Lake Road	System fixed to City of Waterbury Department of Public Health code	Presumed to be contained on the property
Single family residence located at 1136 Chase Parkway	System fixed to City of Waterbury Department of Public Health code	Presumed to be contained on the property
Multi family residence located at 1110 Pearl Lake Road	System fixed to City of Waterbury Department of Public Health code	Presumed to be contained on the property
Multi family residence located at 567 Boyden Street	System fixed to City of Waterbury Department of Public Health code	Presumed to be contained on the property
Multi family residence located at 345 Huntingdon Avenue	System fixed to City of Waterbury Department of Public Health code	Presumed to be contained on the property
Single family residence located at 172 Farrell Road	System fixed to City of Waterbury Department of Public Health code	Presumed to be contained on the property
Single family residence located at 101 Malmalick Avenue	System fixed to City of Waterbury Department of Public Health code	Presumed to be contained on the property
Single family residence located at 95 Hitchcock Road	System fixed to City of Waterbury Department of Public Health code	Presumed to be contained on the property
Single family residence located at 19 Elmhurst Avenue	System fixed to City of Waterbury Department of Public Health code	Presumed to be contained on the property
Commercial property located at 1211 Chase Parkway	New subsurface sewage disposal system installed	No water bodies impacted

Commercial property located at 1209 Chase Parkway	Only soil testing performed due to subdivision of property	N/A
Municipal school located at 1255 Hamilton Avenue	Tank & system removed as part of school demolition	No water bodies impacted
Residential property located at 74 Morton Road	New subsurface sewage disposal system installed	No water bodies impacted

(information obtained from Richard Lee, Chief Sanitarian of the Waterbury Health Department)

3.7 IDDE reporting metrics

Metrics	
Estimated or actual number of MS4 outfalls	~351 presumed city owned outfalls*
Estimated or actual number of interconnections	~19 with State roads identified to date. More to be determined. Interconnections with other towns not yet located.
Outfall mapping complete	~95% Some outfalls need to be reclassified/relabelled. Revisions on-going.
Interconnection mapping complete	TBD. State owned outfalls mapped, but interconnection points not yet identified
System-wide mapping complete (detailed MS4 infrastructure)	~95% Still need additional labelling. Outfall type, size, material and lat/long are included in inventory only. Due to the large # of outfalls in the City, this information would be too busy to be shown on a map.
Outfall assessment and priority ranking	Initial ranking completed*
Dry weather screening of all High and Low priority outfalls complete	294 (includes some potential interconnections)
Catchment investigations complete	0
Estimated percentage of MS4 catchment area investigated	0%

*Of the 85 Ends of Pipes that were initially identified as culverts, 24 were verified to be outfalls, added to the inventory and are presumed to be either low or high priority. They will be dry weather screened and sampled if necessary. From this list, 31 were determined to be true culverts, 6 were state outfalls, 2 were private outfalls and 22 end of pipes were actually inlets.

3.8 Briefly describe the IDDE training for employees involved in carrying out IDDE tasks including what type of training is provided and how often is it given (minimum once per year).

Employees in the City of Waterbury involved in the IDDE program will be trained at a minimum on how to identify illicit discharges and SSOs. Staff will read the IDDE Program Plan and watch the workshop presentations located on the UCONN Nemo website for clarification on their specific duties. Training will be conducted annually (by July 1, 2020) and recorded on the form located in the Appendix of the IDDE Plan.

4. Construction Site Runoff Control (Section 6(a)(4) / page 25)

4.1 BMP Summary

BMP	Status	Activities in current reporting period	Measurable goal	Department / Person Responsible	Due	Date completed or projected completion date	Additional details
4-1 Implement, upgrade, and enforce land use regulations or other legal authority to meet requirements of MS4 general permit	Ongoing	The City's Land Use Regulations as revised through 2016 are currently being enforced	Revise regulations as necessary	PW/Planning/City Engineer	Jul 1, 2019	May revise if necessary	Included in City of Waterbury Zoning regulations under Section 9.06 Stormwater & Erosion Management Standards
4-2 Develop/Implement plan for interdepartmental coordination in site plan review and approval	Ongoing	Interdepartmental meetings are being conducted	As necessary by project	PW/Planning/City Engineer	Ongoing	Implemented by July 1, 2017	
4-3 Review site plans for stormwater quality concerns	Ongoing	Site Plan reviews include the review of stormwater controls or BMPs in accordance with an E&S Control Plan for sites with soil disturbance of one-half acre or more	On-going as required	PW/Planning/City Engineer	Ongoing	Implemented by July 1, 2017	
4-4 Conduct site inspections	Ongoing	The City has been conducting inspections of construction sites to ensure the adequacy of the installation, maintenance, operation & repair of runoff control	On-going as required	PW/Planning/City Engineer	Ongoing	Implemented by July 1, 2017	

		measures					
4-5 Implement procedure to allow public comment on site development	Completed	The public can contact the Citizens Service Center by phone or entering a complaint in the QAlert System on the webiste	Provide notification	PW/Planning/City Engineer	Ongoing	Implemented by July 1, 2017	Information submitted is forwarded to the P&Z and PW Depts. Info regarding construction site runoff is forwarded to the Zoning enforcement officer
4-6 Implement procedure to notify developers about DEEP construction stormwater permit	Completed	Waterbury informs developers that they have a potential obligation to apply for a permit if their construction disturbs >1 acre of land	Provide notification	PW/Planning/City Engineer	Ongoing	Implemented by July 1, 2017	The notification includes a provision that a copy of the SWPPP be provided to the City upon request

Extra space for describing above BMP activities, if needed:

BMP	

4.2 Describe any Construction Site Runoff Control activities planned for the next year, if applicable.

None at this time

5. Post-construction Stormwater Management (Section 6(a)(5) / page 27)

5.1 BMP Summary

BMP	Status	Activities in current reporting period	Measurable goal	Department / Person Responsible	Due	Date completed or projected completion date	Additional details
5-1 Establish and/or update legal authority and guidelines regarding LID and runoff reduction in site development planning	Not Started		Publish guidelines	PW/Planning/ City Engineer	Jul 1, 2021	Anticipate completing by the deadline of July 1, 2021.	
5-2 Enforce LID/runoff reduction requirements for development and redevelopment projects	In Progress	The City will continue to suggest LID/runoff reduction to the Maximum Extent Practical, for development and redevelopment projects	Notify developers	PW/Planning/ City Engineer	Ongoing beginning Jul 1, 2019	Ongoing	The City works with Developers to facilitate meeting permit requirements.
5-3 Identify retention and detention ponds in priority areas	In Progress		Update maps	PW/Planning/ City Engineer	Jul 1, 2019	Ongoing	Work underway
5-4 Implement long-term maintenance plan for stormwater basins and treatment structures	In Progress	Plan created on June 26, 2019	Develop Plan	PW/ City Engineer	Ongoing beginning Jul 1, 2019	Ongoing	Work underway to finalize plan
5-5 DCIA mapping	Not Started		Develop goals	PW/ City Engineer	Jul 1, 2020	Anticipate completing by the deadline of July 1, 2020.	
5-6 Address post-construction issues in areas with pollutants of concern	Not Started		On-going as required	PW/Planning/ City Engineer	Not specified		Waterbury will prioritize those areas for the DCIA retrofit program under BMP 6

Extra space for describing above BMP activities, if needed:

BMP	

5.2 Describe any Post-Construction Stormwater Management activities planned for the next year, if applicable.

None at this time

5.3 Post-Construction Stormwater Management reporting metrics

Metrics	
Baseline (2012) Directly Connected Impervious Area (DCIA)	29% 5,463.65 acres
DCIA disconnected (redevelopment plus retrofits)	List not completed at this time
Retrofits completed	In progress
DCIA disconnected	In progress
Estimated cost of retrofits	In progress
Detention or retention ponds identified	In progress

5.4 Briefly describe the method to be used to determine baseline DCIA.

The UConn NEMO MS4 Map located at <https://nemo.uconn.edu/ms4/tools/ms4map.html> was used to determine the impervious cover clipped to the City of Waterbury boundary. Since most of the City's subregional drainage basins are at 11% or greater impervious cover, the assumption that impervious area is equal to directly connected impervious area was used. Due to the large number of outfalls in the City, Baseline DCIA was calculated and tabulated using subregional drainage basin impervious cover values, rather than for each of the MS4 outfalls.

DRAFT

6. Pollution Prevention/Good Housekeeping (Section 6(a)(6) / page 31)

6.1 BMP Summary

BMP	Status	Activities in current reporting period	Measurable goal	Department / Person Responsible	Due	Date completed or projected completion date	Additional details
6-1 Develop/implement formal employee training program	Ongoing	<p>Formal Industrial SW Permit training was conducted at 2 Public Works City facilities. Separate Training was provided for: pesticide & fertilizer application; proper pool maintenance; spill protocols; vehicle wash protocols; E&S controls for road, building & park repairs; & Work order system for SW system maintenance.</p> <p>Initiated the "Stormwater Management Overview" Online Training (Safe Personnel Training website).</p>	Continue Training. Keep logs of trained personnel	PW/City Engineer	Ongoing	Ongoing. Industrial SW Permit Training 12/17/19 and 12/19/19	All staff within the Engineering & Streets Departments and other key Public Works Bureau Supervisors are required to complete the "Stormwater Management Overview" Online Training (Safe Personnel Training website) in 2019. The City will continue its training program, and make amendments as needed with respect to the following: SOPs consistent with MS4 permit, goals and objectives of SMP, IDDE plan components, and Spill Response protocol and responsibilities.
6-2 Implement MS4 property and operations maintenance	Ongoing	Areas of maintenance include: Parks & Open Space; Pet Waste Mgmt.; Waterfowl Mgmt.; City-owned Buildings, Facilities & Utilities; Vehicles & Equipment; & Leaf Management	Keep records of maintenance	PW/Parks/Waterbury City Staff responsible for maintenance	Ongoing beginning Jul 1, 2018	Implemented by July 1, 2018	Property and operations maintenance is currently underway and will continue for the duration of the permit term

6-3 Implement coordination with interconnected MS4s	Not started		Schedule/ Conduct Meetings	PW/Planning/ City Engineer	Not specified		
6-4 Develop/implement program to control other sources of pollutants to the MS4	Not started		Designate a responsible person(s), investigate, start a log	PW/ City Engineer	Not specified		
6-5 Evaluate additional measures for discharges to impaired waters*	No New Problem Areas Identified	The City continues to add "Do Not Feed the Geese" signs around parks. Many pet waste stations and "Pick-Up After Pet" signs are located in various parks.	Designate responsible person(s), hold meetings, start a log	PW/Parks/ City Engineer	Not specified	Ongoing	
6-6 Track projects that disconnect DCIA	Ongoing	The City has a log to track projects that have disconnected DCIA from the MS4	Maintain spreadsheet/log	PW/Planning/City Engineer	Ongoing	Ongoing	The tracking log has been started and will be updated throughout the duration of the permit
6-7 Implement infrastructure repair/rehab program	Not started	Waterbury will begin to keep a log of MS4 structures requiring repair, rehabilitation, or an upgrade to reduce/eliminate the discharge of pollutants	Create spreadsheet/log Complete projects	PW/City Engineer	Jul 1, 2021	Anticipate completing by the deadline of July 1, 2021	This program will be updated with information gathered during IDDE investigations and monitoring activities
6-8 Develop/implement plan to identify/prioritize retrofit projects	In Progress		Create spreadsheet/log to identify potential DCIA disconnection projects	PW/Planning/City Engineer	Jul 1, 2020	Anticipate completing by the deadline of July 1, 2020	Draft Retrofit Plan prepared recently
6-9 Implement retrofit projects to disconnect 2% of DCIA	Not started		Implement Plan (above)- Goal is to reduce DCIA acreage by 1% each year starting July 1,	PW/Planning/City Engineer	Jul 1, 2022	Anticipate completing by the deadline of July 1, 2022	

			2021				
6-10 Develop/implement street sweeping program	Ongoing	See table in Section 6.3 for 2019 street sweeping statistics. Streets and parking lots within Priority Areas were swept following winter maintenance activities in 2019. This occurs at least once per year. In addition, areas with increased pollutant potential were swept more frequently. Street sweepings were disposed at the North End Disposal Area	Maintain log of street sweeping details	PW/City Engineer	Ongoing beginning Jul 1, 2017	This BMP will continue throughout the duration of the permit. Sweeping started April 15, 2019 and was completed by July 10, 2019. School lots completed by May 4, 2019	The City meets the sweeping frequencies outlined in the SMP, including rural and uncurbed streets and parking lots with no Catch basins. Downtown business area swept monthly from April thru November.
6-11 Develop/implement catch basin cleaning program	Ongoing	The City cleaned catch basins observed to be full based on resident or department work reports or complaints; The City has a designated catch basin cleaning crew during the spring. The City continues to monitor the trash extruders that are still installed in catch basins on high litter areas	Maintain log of catch basin cleanings and inspections. Develop formal program.	PW/City Engineer	Ongoing beginning Jul 1, 2020	This BMP will continue throughout the duration of the permit. Formal program to be completed by the deadline of July 1, 2020	See Table below for 2019 statistics 1100 catch basins were cleaned by City staff. 1000 catch basins were cleaned by an outside contractor.
6-12 Develop/implement snow management practices	Ongoing	The City will continue to brief associated staff at every snow storm on the SOPs for the use, handling, storage, application and disposal of de-	Maintain manual with written SOPs, records of training, log of snow management activities	PW/City Engineer	Ongoing beginning Jul 1, 2018	Ongoing. City hopes to have written SOPs and training for application rates of de-icing materials in the	The City will manage and dispose of snow accumulations in accordance with the DEEP BMP found at www.ct.gov/deep/stormwater The City will continue to

		icing products to minimize exposure to stormwater. City maintains detailed logs of snow management activities and SOPs. See Table below for 2019 snow management statistics				near future.	consider the use of alternative materials to chloride based or other salt deicing products
--	--	---	--	--	--	--------------	--

Extra space for describing above BMP activities, if needed:

BMP	

6.2 Describe any Pollution Prevention/Good Housekeeping activities planned for the next year, if applicable.

Continue with ongoing BMP's described above

6.3 Pollution Prevention/ Good Housekeeping reporting metrics

Metrics	
Employee training provided for key staff	Not MS4 specific. Implemented in 2019.
Street sweeping	
Curb miles swept	650 miles; all municipal & school lots swept April-May 2019
Volume (or mass) of material collected	Data Unavailable
Catch basin cleaning	
Total catch basins in priority areas	6600

Total catch basins in MS4	6600
Catch basins inspected	~3000
Catch basins cleaned	2100
Volume (or mass) of material removed from all catch basins	Data Unavailable
Volume removed from catch basins to impaired waters (if known)	Data Unavailable
Snow management	
Type(s) of deicing material used	Sand and salt (4 parts sand, 1 part salt)
Total amount of each deicing material applied	16,000 cubic yards
Type(s) of deicing equipment used	Sand and salt spreader
Lane-miles treated	325 miles treated multiple times during each snow storm. During this snow season, DPW responded to approx. 36 storm events (38.4" snowfall total).
Snow disposal location	City owned property at 698 South Main Street
Staff training provided on application methods & equipment	Yes. Staff is briefed at every snow storm.
Municipal turf management program actions (for permittee properties in basins with N/P impairments)	
Reduction in application of fertilizers (since start of permit)	N/A
Reduction in turf area (since start of permit)	N/A
Lands with high potential to contribute bacteria (dog parks, parks with open water, & sites with failing septic systems)	
Cost of mitigation actions/retrofits	None at this time

6.4 Catch basin cleaning program

Provide any updates or modifications to your catch basin cleaning program

The City will utilize the citizen service request and work order tracking program called QAlert that includes a mobile app (iReportWTBY) for the public to report catch basins requiring maintenance, to prioritize catch basins to be cleaned. Use of this system aids the City in quantifying annual catch basin maintenance, including cleaning and repairs.

The City will prioritize catch basins near impaired waters and construction sites. Those Catch basins shall be cleaned more frequently.

6.5 Retrofit program

Briefly describe the Retrofit Program identification and prioritization process, the projects selected for implementation, the rationale for the selection of those projects and the total DCIA to be disconnected upon completion of each project.

No information to report at this time.

Describe plans for continuing the Retrofit program and how to achieve a goal of 1% DCIA disconnection in future years.

No information to report at this time.

Describe plans for continuing the Retrofit program beyond this permit term with the goal to disconnect 1% DCIA annually over the next 5 years.

No information to report at this time.

DRAFT

Part II: Impaired waters investigation and monitoring

1. Impaired waters investigation and monitoring program

1.1 Indicate which stormwater pollutant(s) of concern occur(s) in your municipality or institution. This data is available on the MS4 map viewer: <http://s.uconn.edu/ctms4map>.

Nitrogen/ Phosphorus Bacteria Mercury Other Pollutant of Concern

1.2 Describe program status.

Discuss 1) the status of monitoring work completed, 2) a summary of the results and any notable findings, and 3) any changes to the Stormwater Management Plan based on monitoring results.

1)Twenty-four (24) outfalls were screened in 2018 for stormwater pollutants of concern. 2)All 24 outfalls require follow-up. 3)No changes have been made to the Stormwater Management Plan at this time. If, during Follow-up Investigations and Drainage Area Investigation, the need arises to update the Plan, changes will be made at that time.
No additional outfalls were monitored in 2019.

2. Screening data for outfalls to impaired waterbodies (Section 6(i)(1) / page 41)

2.1 Screening data

Complete the table below for any outfalls screened during the reporting period. Each Annual Report will add on to the previous year's screening data showing a cumulative list of outfall screening data.

Outfall ID	Sample date	Parameter (Nitrogen, Phosphorus, Bacteria, or Other pollutant of concern)	Results	Name of Laboratory (if used)	Follow-up required? *
6914-00-3-L4-004	6/29/2018	- Bacteria - Other pollutant of concern	- E. coli 11,370 cfu/100ml - T Coliform 12,100 cfu/100ml - Turbidity of outfall 49.0 NTU - Turbidity upstream 17.0 NTU	CET Subcontracted to PH-0509	Yes
6914-00-3-L4-015	6/29/2018	- Bacteria - Other pollutant of concern	- E. coli 8,570 cfu/100ml - T Coliform 9,600 cfu/100ml - Tubridity of outfall 232.0 NTU - Turbidity upstream	CET Subcontracted to PH-0509	Yes

			27.0 NTU		
6914-00-3-L4-012	6/29/2018	- Bacteria - Other pollutant of concern	- E. coli 8,900 cfu/100ml - T Coliform 9,810 cfu/100ml - Turbidity of outfall 25.0 NTU - Turbidity upstream 20.0 NTU	CET Subcontracted to PH-0509	Yes
6914-00-3-L3-007	6/29/2018	- Bacteria - Other pollutant of concern	- E. coli 8,600 cfu/100ml - T Coliform 10,100 cfu/100ml - Turbidity of outfall 80.0 NTU - Turbidity upstream N/A †	CET Subcontracted to PH-0509	Yes
6914-00-3-L3-008	6/29/2018	- Bacteria - Other pollutant of concern	- E. coli 9,240 cfu/100ml - T Coliform 10,600 cfu/100ml - Turbidity of outfall 92.0 NTU - Turbidity upstream N/A †	CET Subcontracted to PH-0509	Yes
6914-00-3-R3-003	11/13/2018	- Bacteria - Other pollutant of concern	- E. coli 1,732.9 MPN/100ml - T Coliform >2,419.6 MPN/100ml - Turbidity of outfall 16.5 NTU - Turbidity upstream N/A	CET	Yes
6914-00-3-L3-017	11/13/2018	- Bacteria - Other pollutant of concern	- E. coli >2,419.6 MPN/100ml - T Coliform >2,419.6 MPN/100ml - Turbidity of outfall 13.5 NTU - Turbidity upstream N/A	CET	Yes
6914-00-3-R3-008	11/13/2018	- Bacteria - Other pollutant of concern	- E. coli 1,553.1 MPN/100ml - T Coliform >2,419.6 MPN/100ml	CET	Yes
6914-00-3-R3-005	11/13/2018	- Bacteria - Other pollutant of concern	- E. coli 396.08 MPN/100ml - T Coliform >2,419.6 MPN/100ml	CET	Yes
6914-00-3-L3-005	11/13/2018	- Bacteria - Other pollutant of concern	- E. coli 1,986.3 MPN/100ml - T Coliform >2,419.6 MPN/100ml - Turbidity of outfall 17.5 NTU - Turbidity upstream	CET	Yes

			N/A		
6914-00-3-L3-013	11/13/2018	- Bacteria - Other pollutant of concern	- E. coli >2,419.6 MPN/100ml - T Coliform >2,419.6 MPN/100ml	CET	Yes
6914-00-3-L3-003	11/13/2018	- Bacteria - Other pollutant of concern	- E. coli 547.50 MPN/100ml - T Coliform >2,419.6 MPN/100ml - Turbidity of outfall 21.0 NTU - Turbidity upstream N/A	CET	Yes
6914-00-3-L3-001	11/13/2018	- Bacteria - Other pollutant of concern	- E. coli 1,046.2 MPN/100ml - T Coliform >2,419.6 MPN/100ml - Turbidity of outfall 13.0 NTU - Turbidity upstream N/A	CET	Yes
6914-00-3-L3-004	11/13/2018	- Bacteria - Other pollutant of concern	- E. coli 1,732.9 MPN/100ml - T Coliform >2,419.6 MPN/100ml - Turbidity of outfall 6.52 NTU - Turbidity upstream N/A	CET	Yes
6914-00-3-L3-002	11/13/2018	- Bacteria - Other pollutant of concern	- E. coli 1,046.2 MPN/100ml - T Coliform >2,419.6 MPN/100ml - Turbidity of outfall 6.47 NTU - Turbidity upstream N/A	CET	Yes
6914-00-3-L3-002A	11/13/2018	- Bacteria - Other pollutant of concern	- E. coli 261.30 MPN/100ml - T Coliform >2,419.6 MPN/100ml - Turbidity of outfall 11.9 NTU - Turbidity upstream N/A	CET	Yes

6914-00-3-L4-001	12/28/2018	- Bacteria - Other pollutant of concern	- E. coli 749 MPN/100ml - T Coliform >2,000 CFU/100ml - Turbidity of outfall 19.20 NTU - Turbidity upstream 3.35 NTU	Phoenix	Yes
6914-00-3-L4-013	12/28/2018	- Bacteria - Other pollutant of concern	- E. coli 10 MPN/100ml - T Coliform 900 CFU/100ml - Turbidity of outfall 70.50 NTU - Turbidity upstream 16.44 NTU	Phoenix	Yes
6914-00-3-R3-004	12/28/2018	- Bacteria - Other pollutant of concern	- E. coli 706 MPN/100ml - T Coliform >2,000 CFU/100ml - Turbidity of outfall 25.20 NTU - Turbidity upstream 5.75 NTU	Phoenix	Yes
6914-00-3-L3-021A	12/28/2018	- Bacteria - Other pollutant of concern	- E. coli 52 MPN/100ml - T Coliform >2,000 CFU/100ml - Turbidity of outfall 12.45 NTU - Turbidity upstream 3.91 NTU	Phoenix	Yes
6914-00-3-L3-010	12/28/2018	- Bacteria - Other pollutant of concern	- E. coli 52 MPN/100ml - T Coliform >2,000 CFU/100ml - Turbidity of outfall 84.90 NTU - Turbidity upstream 2.10 NTU	Phoenix	Yes
6914-00-3-L3-011	12/28/2018	- Bacteria - Other pollutant of concern	- E. coli 63 MPN/100ml - T Coliform >2,000 CFU/100ml - Turbidity of outfall 43.20 NTU - Turbidity upstream 2.10 NTU	Phoenix	Yes

6914-00-3-R3-018	12/28/2018	- Bacteria - Other pollutant of concern	- E. coli 279 MPN/100ml - T Coliform >2,000 CFU/100ml - Turbidity of outfall 46.10 NTU - Turbidity upstream 4.75 NTU	Phoenix	Yes
6914-00-3-R3-013	12/28/2018	- Bacteria - Other pollutant of concern	- E. coli 620 MPN/100ml - T Coliform >2,000 CFU/100ml - Turbidity of outfall 48.70 NTU - Turbidity upstream 9.30 NTU	Phoenix	Yes

†Upstream turbidity samples were not collected due to inaccessibility of the waterbody.

2.2 Credit for screening data collected under 2004 permit

If any outfalls to impaired waters were sampled under the 2004 MS4 permit, that data can count towards the monitoring requirements under the modified 2017 MS4 permit. Complete the table below to record sampling data for any outfalls to impaired waters under the 2004 MS4 permit.

Outfall	Sample date	Parameter (Nitrogen, Phosphorus, Bacteria, or Other pollutant of concern)	Results	Name of Laboratory (if used)	Follow-up required? *
6912-00-3-R1-002	10/27/2016	Bacteria	- E. coli 41,000 MPN/100ml	Connecticut Testing Laboratories	Yes
6900-00-4-R13-012	10/27/2016	Bacteria	- E. coli 18,600 MPN/100ml	Connecticut Testing Laboratories	Yes
6914-00-3-R3-002	10/27/2016	Bacteria	- E. coli 23,800 MPN/100ml	Connecticut Testing Laboratories	Yes
6900-00-4-R9-002	2000-2006	Bacteria	- 33 E. coli samples with a range of 50-24,000 col/100ml and a median of 11,000 col/100ml	Data found in "A Total Maximum Daily Load Analysis for Recreational Uses of the Naugatuck River Regional Basin" by CT DEEP April 17, 2008	Yes

*Follow-up investigation required (last column) if the following pollutant thresholds are exceeded:

Pollutant of concern	Pollutant threshold
Nitrogen	Total N > 2.5 mg/l
Phosphorus	Total P > 0.3 mg/l
Bacteria (fresh waterbody)	<ul style="list-style-type: none"> E. coli > 235 col/100ml for swimming areas or 410 col/100ml for all others Total Coliform > 500 col/100ml
Bacteria (salt waterbody)	<ul style="list-style-type: none"> Fecal Coliform > 31 col/100ml for Class SA and > 260 col/100ml for Class SB Enterococci > 104 col/100ml for swimming areas or 500 col/100 for all others
Other pollutants of concern	Sample turbidity is 5 NTU > in-stream sample

3. Follow-up investigations (Section 6(i)(1)(D) / page 43)

Provide the following information for outfalls exceeding the pollutant threshold.

Outfall	Status of drainage area investigation	Control measure implementation to address impairment
NA		

4. Prioritized outfall monitoring (Section 6(i)(1)(D) / page 43)

Once outfall screening has been completed for at least 50% of outfalls to impaired waters, identify 6 of the highest contributors of any pollutants of concern. Begin monitoring these outfalls on an annual basis by July 1, 2020.

Outfall	Sample Date	Parameter(s)	Results	Name of Laboratory (if used)
NA				

Part III: Additional IDDE Program Data

1. Assessment and Priority Ranking of Catchments data (Appendix B (A)(7)(c) / page 5)

Provide a list of all catchments with ranking results (DEEP basins may be used instead of manual catchment delineations).

The following information was provided in the 2018 Annual Report. The DEEP Basins have not been re-ranked since then.

In order to assign a Priority Ranking of Catchments by DEEP basin, the method of averaging the IDDE ranking score was used. Scores were taken from the Catchment Assessment and Priority Ranking Matrix (hereafter referred to as the IDDE Ranking Matrix), included in the IDDE Plan. The IDDE Ranking Matrix score of outfalls within each DEEP local drainage basin were averaged and the basins were ranked by the averages, with 1 being the highest ranking and 23 being the lowest. Note that there are some duplicate ranking values as some averages of outfall scores were the same. See Column 3 below for results and below the table for additional background information.

1. Catchment ID (DEEP Basin ID)	2. Category	3. Rank* (Average Outfall score in parantheses)
6900-00-4-R9 Naugatuck River	Low: 1/2 Problem: 1/2	1 (8.50)
6900-00-4-R13 Naugatuck River	Low: 4/14 High: 9/14 Problem: 1/14	2 (7.86)
6900-00-4-R12 Naugatuck River	Low: 3/5 High: 2/5	3 (7.20)
6914-00-3-R2 Mad River	Low: 2/2	4 (6.50)
6914-00-3-L4 Mad River	Low: 13/13	5 (6.23)
6914-00-3-R3 Mad River	Excluded: 1/16 Low: 13/16 High: 1/16 Problem: 1/16	6 (6.06)
6914-00-3-L3 Mad River	Low: 17/17	7 (6.00)
6900-00-4-R15 Naugatuck River	Low: 1/1	7 (6.00)
6913-00-1 Beaver Pond Brook	Problem: 1/1	7 (6.00)
6900-22-1 Naugatuck River	Low: 2/2	8 (5.50)
6900-21-1-L3 Naugatuck River	Low: 1/1	9 (5.00)

6900-22-1-L3 Naugatuck River	Low: 1/1	9 (5.00)
6914-11-1 Mad River	Low: 5/5	10 (4.80)
6912-00-3-R1 Steele Brook	Low: 22/25 Problem: 3/25	11 (4.56)
6900-00-4-R11 Naugatuck River	Excluded: 3/56 Low: 51/56 Problem: 2/56	12 (4.50)
6900-00-4-R14 Naugatuck River	Excluded: 1/5 Low: 4/5	13 (4.40)
6900-22-1-L4 Naugatuck River	Excluded: 1/3 Low: 2/3	14 (4.00)
6913-00-2-R2 Beaver Pond Brook	Low: 4/4	14 (4.00)
6911-00-3-R1 Hancock River	Low: 25/26 Problem: 1/26	15 (3.85)
6900-23-1 Naugatuck River	Low: 6/6	16 (3.50)
6913-00-2-R1 Beaver Pond Brook	Low: 21/21	17 (3.29)
6900-24-1 Naugatuck River	Low: 8/8	18 (3.13)
6900-22-1-L5 Naugatuck River	Low: 1/1	19 (3.00)
6900-22-1-L6 Naugatuck River	Low: 3/3	19 (3.00)
6900-23-1-L1 Naugatuck River	Low: 1/1	19 (3.00)
6900-23-1-L2 Naugatuck River	Low: 2/2	19 (3.00)
6900-23-1-L3 Naugatuck River	Low: 12/12	19 (3.00)
6911-00-3-L9 Hancock River	Low: 1/1	19 (3.00)
6912-06-1 Steele Brook	Low: 1/1	19 (3.00)
6914-08-1 Mad River	Low: 4/4	19 (3.00)
6914-09 Mad River	Low: 1/1	19 (3.00)
6914-09-1-L1 Mad River	Low: 1/1	19(3.00)

6916-11-1 Hop Brook	Low: 3/3	19 (3.00)
6916-11-1-L1 Hop Brook	Low: 14/14	19 (3.00)
6916 10-1 Hop Brook	Low: 7/7	19 (3.00)
6913-03-1 Beaver Pond Brook	Excluded: 2/8 Low: 6/8	20 (2.91)
6900-22-1-L1 Naugatuck River	Excluded: 1/9 Low: 8/9	21(2.90)
6916-00-3-L4 Hop Brook	Low: 5/6 Excluded: 1/6	22 (2.83)
6916-10-1-L1 Hop Brook	Excluded: 3/7 Low: 4/7	23 (2.71)
6913-03-1-L1 Beaver Pond Brook	Low: 2/3 Excluded: 1/3	24 (2.67)
6913-02-1 Beaver Pond Brook	Excluded: 11/25 Low: 14/25	25 (2.56)
6911-00-3-L8 Hancock River	Excluded: 4/7 Low: 3/7	26 (2.43)
6913-01-1 Beaver Pond Brook	Excluded: 4/6 Low: 2/6	27 (2.33)
6900-22-1-L2 Naugatuck River	Excluded: 1/1	28 (2.00)

*Overall Basin Rank based on average score of outfalls from IDDE Ranking Matrix

Background

The IDDE Ranking Matrix was used to score each individual outfall based on available catchment characteristics information. The outfalls in the IDDE Ranking Matrix were grouped by DEEP's local drainage basins and were assigned IDs based on these basin numbers. Outfalls were assigned to a priority category (excluded, low, high or problem) based on their score in the IDDE Ranking Matrix. The characteristics, and consequently the score and priority category, of each of the outfalls within a local drainage basin were not uniform. Therefore the associated local drainage basin could not be directly assigned a single priority category and the averages of outfall scores for each drainage basin were used for the table above.

Dry weather screening and sampling began in June of 2018, with outfalls designated as low or high priority within priority areas in drainage basins to Impaired Waterbodies first, in order to meet the permit deadline of July 1, 2018. However, the outfall inventory and ranking had not been completed at this time. Screening and sampling started within the Mad River basins, followed by the Steele Brook and the Naugatuck River basins. Outfalls screened and sampled were located in areas where a significant amount of outfalls are in close proximity to each other to maximize time in the field. The City of Waterbury will continue to dry weather screen and sample outfalls within the DEEP local drainage basins with the highest rankings as listed above.

The following limitations and assumptions were made as part of the IDDE activities:

- Outfalls that had prior evidence of sewer impacts from analytical data or are located in close proximity to and downgradient from properties with failing septic systems were categorized as "Problem".

- In addition to assigning an outfall to an “Excluded” category based on the score in the IDDE Ranking Matrix, outfalls were also checked for characteristics for “excluded catchments” as defined in the permit.
- Outfalls determined to be from private properties or roads, state owned roads, inlets, true culverts or outfalls that discharge to wooded areas and not to “waters of the state”, either from field reconnaissance or office research, were removed from the original list/total of outfalls found in the original IDDE Plan dated June 29, 2018.
- City-owned outfalls were prioritized for dry weather screening and sampling over interconnections and culverts. Only some interconnections and culverts were listed and ranked in the current IDDE Ranking Matrix.
- **Update for 2019:** Of the 85 Ends of Pipes(outfalls) that were initially identified as culverts, 24 were verified to be outfalls, added to the inventory and are presumed to be either low or high priority. They will be dry weather screened, and sampled and investigated if necessary. From this list, 31 were determined to be true culverts, 6 were state outfalls, 2 were private outfalls and 22 end of pipes were actually inlets.
- Once the locations and details of the additional interconnections can be verified, they will be added to the inventory and dry weather screened, and sampled and investigated if necessary.

2. Outfall and Interconnection Screening and Sampling data (Appendix B (A)(7)(d) / page 7)

2.1 Dry weather screening and sampling data from outfalls and interconnections

Provide sample data for outfalls where flow is observed. Only include Pollutant of concern data for outfalls that discharge into stormwater impaired waterbodies.

Outfall / Interconnection ID	Screening / Sample Date	Ammonia	+Chlorine	Conductivity	Salinity	E. coli or Enterococcus	Surfactants	Water Temp	Pollutant of Concern	If required, follow-up actions taken
6913-00-2-R1-011	4/5/2011*	-	-	-	-	-	-	-	n/a	N/A
6911-00-3-R1-022	7/21/2011*	-	-	-	-	-	-	-	Other	N/A
6914-00-3-R3-008	1/30/2012*	-	-	-	-	-	-	-	E. coli & Other	N/A
6900-00-4-R11-014	1/30/2014*	-	-	-	-	-	-	-	E. coli & Other	N/A
6916-11-1-L1-007	7/18/2014*	-	-	-	-	-	-	-	n/a	N/A
6916-11-1-L1-008	7/1/2016*	-	-	-	-	-	-	-	n/a	N/A
6900-00-4-R14-005	7/22/2016*	-	-	-	-	-	-	-	E. coli & Other	N/A
6914-00-3-L4-015	6/7/2018	-	-	-	-	-	-	-	E. coli & Other	N/A
6914-00-3-L4-014	6/7/2018	-	-	-	-	-	-	-	E. coli & Other	N/A

6914-00-3-L4-013	6/7/2018	-	-	-	-	-	-	-	-	E. coli & Other	N/A
6914-00-3-L4-012	6/7/2018	-	-	-	-	-	-	-	-	E. coli & Other	N/A
6914-00-3-L4-009	6/7/2018	-	-	-	-	-	-	-	-	E. coli & Other	N/A
6914-00-3-L4-008	6/7/2018	-	-	-	-	-	-	-	-	E. coli & Other	N/A
6914-00-3-L4-007	6/7/2018	-	-	-	-	-	-	-	-	E. coli & Other	N/A
6914-00-3-L4-005	6/7/2018	-	-	-	-	-	-	-	-	E. coli & Other	N/A
6914-00-3-L3-021	6/7/2018	-	-	-	-	-	-	-	-	E. coli & Other	N/A
6914-00-3-L3-021a	6/7/2018	-	-	-	-	-	-	-	-	E. coli & Other	N/A
6914-00-3-L3-013	6/7/2018	-	-	-	-	-	-	-	-	E. coli & Other	N/A
6914-00-3-L3-011	6/7/2018	-	-	-	-	-	-	-	-	E. coli & Other	Odor and brown sludge present. Will be ranked at top of high priority category for catchment investigation
6914-00-3-L3-005	6/7/2018	-	-	-	-	-	-	-	-	E. coli & Other	N/A
6914-00-3-L3-002	6/7/2018	-	-	-	-	-	-	-	-	E. coli & Other	N/A
6914-00-3-L3-019	6/8/2018	-	-	-	-	-	-	-	-	n/a	N/A
6914-00-3-L3-018	6/8/2018	-	-	-	-	-	-	-	-	n/a	N/A
6914-00-3-R3-013	6/8/2018	-	-	-	-	-	-	-	-	E. coli & Other	N/A
6914-00-3-R3-012	6/8/2018	-	-	-	-	-	-	-	-	E. coli & Other	N/A
6914-11-1-012	7/31/2018	-	-	-	-	-	-	-	-	n/a	N/A
6914-11-1-010	7/31/2018	-	-	-	-	-	-	-	-	n/a	N/A
6914-11-1-006	7/31/2018	-	-	-	-	-	-	-	-	n/a	N/A
6914-11-1-005	7/31/2018	-	-	-	-	-	-	-	-	n/a	N/A

6914-11-1-004	7/31/2018	<0.10 mg/l	Not detected	491.5 uS/cm	0.3 ppt	E. coli 65.00 MPN/100ml	<0.05 mg/l	20 C	n/a	N/A
6914-11-1-003	7/31/2018	0.22 mg/l	Not detected	676 uS/cm	0.4 ppt	E. coli 727.00 MPN/100ml	<0.05 mg/l	21 C	n/a	Will raise priority category from low to high for potential catchment investigation
6914-11-1-002**	7/31/2018	<0.10 mg/l	0.6 mg/l	181.6 uS/cm	0.1 ppt	E. coli <1 MPN/100ml	<0.05 mg/l	20 C	n/a	Will be ranked at top of high priority category for catchment investigation
6914-11-1-001	7/31/2018	<0.10 mg/l	Not detected	399.3 uS/cm	0.2 ppt	E. coli 24.7 MPN/100mL	<0.05 mg/l	20.1 C	n/a	N/A
6914-08-1-002	7/31/2018	1.3 mg/l	Not detected	469 uS/cm	0.4 ppt	E. coli >2,419.6 MPN/100ml	<0.05 mg/l	19 C	n/a	Will be ranked at top of high priority category for catchment investigation
6914-10-01-001	7/31/2018	-	-	-	-	-	-	-	n/a	N/A
6914-08-1-003	7/31/2018	-	-	-	-	-	-	-	n/a	N/A
6914-08-1-001	7/31/2018	-	-	-	-	-	-	-	n/a	N/A
6912-00-3-R1-013	11/12/2018	<0.10 mg/l	Not detected	316 uS/cm	0.15 ppt	E. coli 107.60 MPN/100ml	<0.05 mg/l	1.1 C	E. coli	N/A
6912-00-3-R1-011	11/12/2018	<0.10 mg/l	Not detected	357 uS/cm	0.17 ppt	E. coli 770.10 MPN/100ml	<0.05 mg/l	1.1 C	n/a	Will raise priority category from low to high for potential catchment investigation
6912-00-3-R1-037	11/29/2018	0.07 mg/l	Not detected	582 uS/cm	0.28 ppt	E. coli <10 MPN/100ml	<0.05 mg/l	6.35 C	E. coli	N/A
6912-00-3-R1-004	11/29/2018	<0.05 mg/l	Not detected	338 uS/cm	0.16 ppt	E. coli 75 MPN/100ml	<0.05 mg/l	7.52 C	E. coli & Other	N/A
6912-00-3-R1-026	11/29/2018	-	-	-	-	-	-	-	n/a	N/A
6912-00-3-R1-006	11/29/2018	<0.05 mg/l	Not detected	217 uS/cm	0.10 ppt	E. coli 988 MPN/100ml	<0.05 mg/l	6.13 C	E. coli	Will raise priority category from low to high for potential catchment investigation
6912-00-3-R1-006a	11/29/2018	<0.10 mg/l	Not detected	328 uS/cm	0.24 ppt	E. coli 30 MPN/100 ml	<0.05 mg/l	6.9 C	E. coli & Other	N/A
6912-06-1-001	12/6/2018	-	-	-	-	-	-	-	n/a	N/A
6912-00-3-R1-009	12/6/2018	<0.05 mg/l	Not detected	307 uS/cm	0.15 ppt	E. coli <10 MPN/100ml	<0.05 mg/l	5.34 C	n/a	N/A
6912-00-3-R1-012	12/6/2018	<0.05 mg/l	Not detected	213 uS/cm	0.10 ppt	E. coli 199 MPN/100ml	<0.05 mg/l	6.6 C	n/a	N/A
6912-00-3-R1-030	12/6/2018	-	-	-	-	-	-	-	n/a	N/A

6912-00-3-R1-025	12/6/2018	0.07 mg/l	Not detected	356 uS/cm	0.17 ppt	E. coli 30 MPN/100ml	<0.05 mg/l	8.51 C	n/a	N/A
6912-00-3-R1-021	12/6/2018	-	-	-	-	-	-	-	n/a	N/A
6912-00-3-R1-017	12/6/2018	0.29 mg/l	Not detected	369 uS/cm	0.18 ppt	E. coli >24,200 MPN/100ml	0.34 mg/l	8.06 C	n/a	Will be ranked at top of high priority category for catchment investigation
6912-00-3-R1-016	12/6/2018	-	-	-	-	-	-	-	n/a	N/A
6912-00-3-R1-010	12/6/2018	-	-	-	-	-	-	-	E. coli	N/A
6912-00-3-R1-014	12/6/2018	-	-	-	-	-	-	-	E. coli	N/A
6914-00-3-R2-008	12/11/2018	-	-	-	-	-	-	-	n/a	N/A
6914-09-1-L1-001	12/11/2018	-	-	-	-	-	-	-	n/a	N/A
6914-00-3-L4-004	12/11/2018	-	-	-	-	-	-	-	E. coli & Other	N/A
6914-00-3-L3-012	12/11/2018	-	-	-	-	-	-	-	E. coli & Other	N/A
6914-00-3-L3-020	12/11/2018	-	-	-	-	-	-	-	n/a	N/A
6914-00-3-L3-007	12/11/2018	0.17 mg/l	Not detected	223.6 uS/cm	0.11 ppt	E. coli 20 MPN/100ml	<0.05 mg/l	1.8 C	E. coli & Other	N/A
6914-00-3-L3-008	12/11/2018	<0.05 mg/l	Not detected	0 uS/cm	0 ppt	E. coli 10 MPN/100ml	<0.05 mg/l	4.4 C	E. coli & Other	N/A
6914-00-3-L3-004	12/11/2018	<0.05 mg/l	Not detected	350 uS/cm	0.17 ppt	E. coli <10 MPN/100ml	<0.05 mg/l	7 C	E. coli & Other	N/A
6914-00-3-L4-006	12/12/2018	<0.05 mg/l	Not detected	192.1 uS/cm	0.09 ppt	E. coli 108 MPN/100ml	<0.05 mg/l	7.2 C	E. coli & Other	N/A
6914-00-3-L3-017	12/12/2018	<0.05 mg/l	Not detected	210.5 uS/cm	0.10 ppt	E. coli <10 MPN/100ml	<0.05 mg/l	10.1 C	n/a	N/A
6914-00-3-R3-004	12/12/2018	<0.10 mg/l	Not detected	0 uS/cm	0 ppt	E. coli 52 MPN/100ml	<0.05 mg/l	9.4 C	E. coli & Other	N/A
6914-00-3-R3-011	12/12/2018	<0.05 mg/l	Not detected	250.4 uS/cm	0.12 ppt	E. coli 10 MPN/100ml	<0.05 mg/l	7.9 C	E. coli & Other	N/A
6914-00-3-R3-006	12/12/2018	<0.05 mg/l	Not detected	712.5 uS/cm	0.35 ppt	E. coli <10 MPN/100ml	<0.05 mg/l	7.4 C	E. coli & Other	N/A
6914-00-3-R3-007	12/12/2018	-	-	-	-	-	-	-	E. coli & Other	N/A
6914-00-3-R3-016	12/12/2018	-	-	-	-	-	-	-	E. coli & Other	N/A

6900-00-4-R11-068	12/13/2018	-	-	-	-	-	-	-	n/a	N/A
6900-00-4-R11-009	12/13/2018	-	-	-	-	-	-	-	n/a	N/A
6900-00-4-R11-055	12/13/2018	-	-	-	-	-	-	-	n/a	N/A
6900-00-4-R11-030	12/13/2018	-	-	-	-	-	-	-	n/a	N/A
6900-00-4-R11-002	12/13/2018	-	-	-	-	-	-	-	n/a	N/A
6900-00-4-R11-012	12/13/2018	-	-	-	-	-	-	-	n/a	N/A
6900-00-4-R11-003	12/13/2018	-	-	-	-	-	-	-	n/a	N/A
6900-00-4-R11-062	12/13/2018	-	-	-	-	-	-	-	n/a	N/A
6900-00-4-R11-061	12/13/2018	-	-	-	-	-	-	-	n/a	N/A
6900-00-4-R11-063	12/13/2018	-	-	-	-	-	-	-	n/a	N/A
6900-22-1-L1-002	12/13/2018	-	-	-	-	-	-	-	n/a	N/A
6900-22-1-L1-001	12/13/2018	-	-	-	-	-	-	-	n/a	N/A
6900-00-4-R14-001	12/14/2018	-	-	-	-	-	-	-	<i>E. coli & Other</i>	N/A
6900-00-4-R14-003	12/14/2018	<0.05 mg/l	Not detected	325.7 uS/cm	0.16 ppt	<i>E. coli 110 MPN/100ml</i>	<0.05 mg/l	9.1 C	<i>E. coli & Other</i>	N/A
6900-00-4-R14-002	12/14/2018	-	-	-	-	-	-	-	<i>E. coli & Other</i>	N/A
6900-24-1-010	12/14/2018	-	-	-	-	-	-	-	n/a	N/A
6900-24-1-009	12/14/2018	<0.05 mg/l	Not detected	204.3 uS/cm	0.10 ppt	<i>E. coli 110 MPN/100ml</i>	<0.05 mg/l	6.8 C	n/a	N/A
6900-24-1-001	12/14/2018	-	-	-	-	-	-	-	n/a	N/A
6900-24-1-005	12/14/2018	<0.05 mg/l	Not detected	365.2 uS/cm	0.17 ppt	<i>E. coli 1,240 MPN/100ml</i>	<0.05 mg/l	4.7 C	n/a	<i>Will raise priority category from low to high for potential catchment investigation</i>
6900-22-1-L1-012	12/14/2018	<0.05 mg/l	Not detected	159.6 uS/cm	0.08 ppt	<i>E. coli 327 MPN/100ml</i>	<0.05 mg/l	8.9 C	n/a	N/A
6900-22-1-L1-013	12/14/2018	-	-	-	-	-	-	-	n/a	N/A

6900-22-1-L1-003	12/14/2018	-	-	-	-	-	-	-	n/a	N/A
6900-00-4-R13-025	12/19/2018	0.06 mg/l	Not detected	886 uS/cm	0.64 ppt	E. coli 31 MPN/100ml	<0.05 mg/l	8.6 C	E. coli & Other	N/A
6900-00-4-R13-017	12/19/2018	-	-	-	-	-	-	-	E. coli & Other	N/A
6900-004-R13-018	12/19/2018	0.08 mg/l	Not detected	794.7 uS/cm	0.39 ppt	E. coli <10 MPN/100ml	<0.05 mg/l	5.6 C	E. coli & Other	N/A
6900-00-4-R13-015	12/19/2018	-	-	-	-	-	-	-	E. coli & Other	N/A
6900-00-4-R13-014	12/19/2018	<0.05 mg/l	Not detected	348.1 uS/cm	0.17 ppt	E. coli <10 MPN/100ml	<0.05 mg/l	6.5 C	E. coli & Other	N/A
6900-00-4-R13-013	12/19/2018	-	-	-	-	-	-	-	E. coli & Other	N/A
6900-00-4-R13-006	12/19/2018	0.05 mg/l	Not detected	550.7 uS/cm	0.27 ppt	E. coli <10 MPN/100ml	<0.05 mg/l	5.7 C	E. coli & Other	N/A
6900-00-4-R13-005	12/19/2018	0.05 mg/l	Not detected	972 uS/cm	0.40 ppt	E. coli <10 MPN/100ml	<0.05 mg/l	7.5 C	E. coli & Other	N/A
6900-00-4-R13-002	12/19/2018	-	-	-	-	-	-	-	E. coli & Other	N/A
6900-00-4-R13-003	12/19/2018	0.59 mg/l	Not detected	502.7 uS/cm	0.24 ppt	E. coli >24,200 MPN/100ml	1.33 mg/l	7.4 C	E. coli & Other	Sewage odor, ammonia, surfactants, & bacteria exceed minimal values. Will be ranked at top of high priority category for catchment investigation
6900-00-4-R13-004	12/19/2018	<0.05 mg/l	Not detected	588 uS/cm	0.43 ppt	E. coli <10 MPN/100ml	0.06 mg/l	7.3 C	E. coli & Other	N/A
6900-00-4-R13-007	12/19/2018	0.10 mg/l	Not detected	500 uS/cm	0.37 ppt	E. coli 2,990 MPN/100ml	<0.05 mg/l	7.1 C	E. coli & Other	Foam noted. Will be ranked at top of high priority category for catchment investigation
6900-00-4-R13-010	12/19/2018	-	-	-	-	-	-	-	E. coli & Other	N/A
6900-00-4-R13-012	12/19/2018	-	-	-	-	-	-	-	E. coli & Other	N/A
6900-00-4-R13-008	12/19/2018	-	-	-	-	-	-	-	E. coli & Other	N/A
6900-00-4-R13-009	12/19/2018	-	-	-	-	-	-	-	E. coli & Other	N/A
6914-11-1-005	1/14/2019	-	-	-	-	-	-	-	n/a	N/A
6900-00-4-R12-003	6/25/2019	-	-	-	-	-	-	-	E. coli & Other	N/A

6900-00-4-R12-004	6/25/2019	-	-	-	-	-	-	-	-	E. coli & Other	N/A
6914-00-3-R3-003	7/11/2019	0.11 mg/l	0.2 mg/l	322 uS/cm	0.15 ppt	>24,200 MPN/100ml	<0.05 mg/l	21.24 C	E. coli & Other	Will be ranked at top of high priority category for catchment investigation	
6914-00-3-R3-001	7/11/2019	-	-	-	-	-	-	-	E. coli & Other	N/A	
6914-00-3-R2-010	7/11/2019	-	-	-	-	-	-	-	n/a	N/A	
6914-00-3-L3-001	7/11/2019	-	-	-	-	-	-	-	E. coli & Other	N/A	
6914-00-3-L3-002a	7/11/2019	-	-	-	-	-	-	-	E. coli & Other	N/A	
6914-00-3-L3-003	7/11/2019	<0.05 mg/l	Not detected	256 uS/cm	0.12 ppt	E. coli 1110 MPN/100ml	<0.05 mg/l	17.42 C	E. coli & Other	Will raise priority category from low to high for potential catchment investigation	
6914-00-3-L3-010	7/11/2019	-	-	-	-	-	-	-	E. coli & Other	N/A	
6900-00-4-R15-007	7/11/2019	<0.05 mg/l	Not detected	220 uS/cm	0.10 ppt	E. coli <10 MPN/100ml	<0.05 mg/l	17.62 C	E. coli & Other	N/A	
6900-00-4-R12-005	7/11/2019	<0.05 mg/l	0.4 mg/l	1212 uS/cm	0.6 ppt	E. coli <10 MPN/100ml	<0.05 mg/l	19.89 C	E. coli & Other	Will raise priority category from low to high for potential catchment investigation	
6900-00-4-R12-002	7/11/2019	-	-	-	-	-	-	-	E. coli & Other	N/A	
6900-00-4-R12-001	7/11/2019	0.16 mg/l	Not detected	305 uS/cm	0.15 ppt	E. coli 14,100 MPN/100ml	<0.05 mg/l	19.93 C	E. coli & Other	Will raise priority category from low to high for potential catchment investigation	
6900-22-1-003	7/11/2019	-	-	-	-	-	-	-	n/a	N/A	
6900-22-1-L4-002	7/11/2019	0.06 mg/l	Not detected	231 uS/cm	0.11 ppt	E. coli 31 MPN/100ml	<0.05 mg/l	18.23 C	E. coli	N/A	
6900-00-4-R11-045	7/15/2019	-	-	-	-	-	-	-	E. coli & Other	N/A	
6900-00-4-R11-008	7/15/2019	-	-	-	-	-	-	-	E. coli & Other	N/A	
6900-00-4-R11-036	7/15/2019	0.21 mg/l	0.2 mg/l	572 uS/cm	0.28 ppt	E. coli >24,200 MPN/100ml	0.78 mg/l	20.52 C	E. coli & Other	Will be ranked at top of high priority category for catchment investigation	
6900-00-4-R11-035	7/15/2019	-	-	-	-	-	-	-	E. coli & Other	N/A	
6900-00-4-R11-013	7/15/2019	-	-	-	-	-	-	-	E. coli & Other	N/A	

6900-00-4-R11-007	7/15/2019	-	-	-	-	-	-	-	-	E. coli & Other	N/A
6911-00-3-L9-001	7/15/2019	-	-	-	-	-	-	-	-	n/a	N/A
6900-00-4-R9-039	7/15/2019	-	-	-	-	-	-	-	-	E. coli & Other	N/A
6900-00-4-R9-038	7/15/2019	-	-	-	-	-	-	-	-	E. coli & Other	N/A
6900-00-4-R9-037	7/15/2019	-	-	-	-	-	-	-	-	E. coli & Other	N/A
6900-00-4-R9-036	7/15/2019	-	-	-	-	-	-	-	-	E. coli & Other	N/A
6900-00-4-R9-035	7/15/2019	-	-	-	-	-	-	-	-	n/a	N/A
6900-00-4-R9-005	7/15/2019	-	-	-	-	-	-	-	-	E. coli & Other	N/A
6900-00-4-R13-011	7/15/2019	-	-	-	-	-	-	-	-	E. coli & Other	N/A
6900-00-4-R13-021	7/15/2019	-	-	-	-	-	-	-	-	E. coli & Other	N/A
6900-00-4-R13-001	7/15/2019	-	-	-	-	-	-	-	-	E. coli & Other	N/A
6900-00-4-R11-058	7/25/2019	-	-	-	-	-	-	-	-	E. coli & Other	N/A
6900-00-4-R11-057	7/25/2019	0.42 mg/l	0.2 mg/l	992 uS/cm	0.49 ppt	E. coli >24,200 MPN/100ml	<0.05 mg/l	23.25 C	E. coli & Other	Will be ranked at top of high priority category for catchment investigation	
6900-00-4-R11-066	7/25/2019	-	-	-	-	-	-	-	-	E. coli & Other	N/A
6900-00-4-R11-059	7/25/2019	-	-	-	-	-	-	-	-	E. coli & Other	N/A
6900-00-4-R11-060	7/25/2019	-	-	-	-	-	-	-	-	E. coli & Other	N/A
6900-00-4-R11-037	7/25/2019	<0.05 mg/l	Not detected	730 uS/cm	0.36 ppt	E. coli 282 MPN/100ml	<0.05 mg/l	21.96 C	E. coli & Other	N/A	
6900-00-4-R11-034	7/25/2019	-	-	-	-	-	-	-	-	E. coli & Other	
6900-00-4-R13-022	7/25/2019	<0.05 mg/l	0.1 mg/l	815 uS/cm	0.4 ppt	E. coli 10 MPN/100ml	<0.05 mg/l	24.05 C	E. coli & Other	Will raise priority category from low to high for potential catchment investigation	
6900-00-4-R11-072	7/25/2019	-	-	-	-	-	-	-	-	n/a	N/A

6900-00-4-R11-052	7/25/2019	-	-	-	-	-	-	-	n/a	N/A
6900-00-4-R11-019	7/25/2019	0.12 mg/l	0.1 mg/l	192 uS/cm	0.09 ppt	E. coli 52 MPN/100ml	<0.05 mg/l	20.97 C	n/a	Will raise priority category from low to high for potential catchment investigation
6900-00-4-R11-074	7/25/2019	-	-	-	-	-	-	-	n/a	N/A
6900-00-4-R11-028	7/25/2019	<0.05 mg/l	0.2 mg/l	347 uS/cm	0.17 ppt	E. coli 95 MPN/100ml	<0.05 mg/l	18.23 C	n/a	Will raise priority category from low to high for potential catchment investigation
6900-00-4-R11-023	7/25/2019	<0.05 mg/l	0.3 mg/l	256 uS/cm	0.12 ppt	E. coli 14,100 MPN/100ml	0.14 mg/l	18.89 C	n/a	Will be ranked at top of high priority category for catchment investigation
6900-00-4-R11-022	7/25/2019	-	-	-	-	-	-	-	n/a	N/A
6911-00-3-R1-007	7/26/2019	<0.05 mg/l	Not detected	300 uS/cm	0.14 ppt	E. coli 676 MPN/100ml	<0.05 mg/l	21.57 C	n/a	Will be scheduled for catchment investigation (previous data also indicated high bacteria during rain event)
6911-00-3-R1-026	7/26/2019	-	-	-	-	-	-	-	n/a	N/A
6911-00-3-R1-036	7/26/2019	<0.05 mg/l	Not detected	374 uS/cm	0.18 ppt	E. coli <10 MPN/100ml	0.13 mg/l	19.53 C	n/a	N/A
6911-00-3-R1-032	7/26/2019	<0.05 mg/l	Not detected	396 uS/cm	0.19 ppt	E. coli 75 MPN/100ml	<0.05 mg/l	18.61	n/a	N/A
6911-00-3-R1-037	7/26/2019	-	-	-	-	-	-	-	n/a	N/A
6911-00-3-R1-029	7/26/2019	<0.05 mg/l	0.1 mg/l	390 uS/cm	0.19 ppt	E. coli 52 MPN/100ml	<0.05 mg/l	20.71	n/a	Will raise priority category from low to high for potential catchment investigation
6911-00-3-R1-031	7/26/2019	-	-	-	-	-	-	-	n/a	N/A
6912-00-3-R1-042	7/26/2019	<0.05 mg/l	0.1 mg/l	466 uS/cm	0.22 ppt	E. coli 728 MPN/100ml	<0.05 mg/l	20.26 C	n/a	Will raise priority category from low to high for potential catchment investigation
6912-00-3-R1-006a	7/26/2019	-	-	-	-	-	-	-	E. coli	N/A
6912-00-3-R1-036a	7/26/2019	-	-	-	-	-	-	-	n/a	N/A
6912-00-3-R1-024	7/26/2019	0.05 mg/l	Not detected	207 uS/cm	0.1 ppt	E. coli 1020 MPN/100ml	<0.05 mg/l	19.99 C	n/a	Will raise priority category from low to high for potential catchment investigation

6900-00-4-R11-064	7/26/2019	0.10 mg/l	0.1 mg/l	204 uS/cm	0.1 ppt	E. coli 146 MPN/100ml	0.07 mg/l	19.37 C	n/a	Will raise priority category from low to high for potential catchment investigation
6900-00-4-R11-053	7/26/2019	0.19 mg/l	0.1 mg/l	285 uS/cm	0.14 ppt	E. coli 728 MPN/100ml	<0.05 mg/l	20.69 C	n/a	Will raise priority category from low to high for potential catchment investigation
6911-00-3-R1-017	7/31/2019	-	-	-	-	-	-	-	Other	N/A
6911-00-3-R1-019a	7/31/2019	-	-	-	-	-	-	-	Other	N/A
6911-00-3-R1-019	7/31/2019	-	-	-	-	-	-	-	Other	N/A
6911-00-3-R1-020	7/31/2019	<0.05 mg/l	0.3 mg/l	138 uS/cm	0.06 ppt	E. coli <10 MPN/100ml	<0.05 mg/l	26.53 C	Other	Will raise priority category from low to high for potential catchment investigation
6911-00-3-R1-021	7/31/2019	-	-	-	-	-	-	-	Other	N/A
6911-00-3-R1-006a	7/31/2019	-	-	-	-	-	-	-	n/a	N/A
6911-00-3-R1-006	7/31/2019	<0.05 mg/l	Not detected	443 uS/cm	0.21 ppt	E. coli 631 MPN/100ml	<0.05 mg/l	20.71 C	n/a	Will raise priority category from low to high for potential catchment investigation
6911-00-3-R1-002	7/31/2019	<0.05 mg/l	0.1 mg/l	380 uS/cm	0.18 ppt	E. coli 146 MPN/100ml	<0.05 mg/l	20.20 C	n/a	Will raise priority category from low to high for potential catchment investigation
6911-00-3-R1-023	7/31/2019	0.43 mg/l	Not detected	450 uS/cm	0.22 ppt	E. coli <10 MPN/100ml	<0.05 mg/l	22.28 C	n/a	N/A
6911-00-3-R1-003	7/31/2019	-	-	-	-	-	-	-	n/a	N/A
6911-00-3-L8-009	7/31/2019	-	-	-	-	-	-	-	n/a	N/A
6911-00-3-L8-004	7/31/2019	-	-	-	-	-	-	-	n/a	N/A
6911-00-3-L8-003	7/31/2019	-	-	-	-	-	-	-	n/a	N/A
6900-23-1-L2-004	8/2/2019	-	-	-	-	-	-	-	n/a	N/A
6900-23-1-L1-001	8/2/2019	0.08 mg/l	0.3 mg/l	354 uS/cm	0.17 ppt	E. coli 1470 MPN/100ml	<0.05 mg/l	21.28 C	n/a	Will be ranked at top of high priority category for catchment investigation
6900-23-1-L2-001	8/2/2019	0.16 mg/l	0.1 mg/l	255 uS/cm	0.12 ppt	E. coli 96 MPN/100ml	<0.05 mg/l	21.6 C	n/a	Will raise priority category from low to high for potential catchment investigation

6900-23-1-001	8/2/2019	0.18 mg/l	0.3 mg/l	291 uS/cm	0.14 ppt	E. coli 146 MPN/100ml	0.06 mg/l	20.3 C	n/a	Will raise priority category from low to high for potential catchment investigation
6900-23-1-L3-002	8/2/2019	<0.05 mg/l	0.5 mg/l	145 uS/cm	0.07 ppt	E. coli <10 MPN/100ml	<0.05 mg/l	21.54 C	n/a	Will raise priority category from low to high for potential catchment investigation
6900-23-1-L3-016	8/2/2019	-	-	-	-	-	-	-	n/a	N/A
6900-23-1-L3-014	8/2/2019	<0.05 mg/l	0.1 mg/l	205 uS/cm	0.1 ppt	E. coli <10 MPN/100ml	<0.05 mg/l	16.9 C	n/a	Will raise priority category from low to high for potential catchment investigation
6900-23-1-L3-015	8/2/2019	-	-	-	-	-	-	-	n/a	N/A
6900-23-1-009	8/2/2019	-	-	-	-	-	-	-	n/a	N/A
6900-23-1-002	8/2/2019	0.12 mg/l	Not detected	254 uS/cm	0.12 ppt	E. coli 109 MPN/100ml	<0.05 mg/l	19.3 C	n/a	N/A
6900-23-1-L3-013	8/2/2019	-	-	-	-	-	-	-	n/a	N/A
6900-23-1-L3-012	8/2/2019	-	-	-	-	-	-	-	n/a	N/A
6900-23-1-L3-007	8/2/2019	-	-	-	-	-	-	-	n/a	N/A
6900-23-1-L3-008	8/2/2019	-	-	-	-	-	-	-	n/a	N/A
6913-00-2-R1-033	8/6/2019	-	-	-	-	-	-	-	n/a	N/A
6913-00-2-R1-032	8/6/2019	-	-	-	-	-	-	-	n/a	N/A
6913-00-2-R1-001	8/6/2019	<0.05 mg/l	0.1 mg/l	618 uS/cm	0.3 ppt	E. coli <10 MPN/100ml	<0.05 mg/l	20.46 C	n/a	Will raise priority category from low to high for potential catchment investigation
6913-00-2-R1-020	8/6/2019	-	-	-	-	-	-	-	n/a	N/A
6913-00-2-R1-019	8/6/2019	-	-	-	-	-	-	-	n/a	N/A
6913-00-2-R1-003	8/6/2019	-	-	-	-	-	-	-	n/a	N/A
6913-00-2-R1-024	8/6/2019	-	-	-	-	-	-	-	n/a	N/A
6913-00-2-R1-017	8/6/2019	-	-	-	-	-	-	-	n/a	N/A

6913-00-2-R1-018	8/6/2019	<0.05 mg/l	0.1 mg/l	350 uS/cm	0.17 ppt	E. coli <10 MPN/100ml	<0.05 mg/l	19.5 C	n/a	Will raise priority category from low to high for potential catchment investigation
6913-00-2-R1-022	8/6/2019	-	-	-	-	-	-	-	n/a	N/A
6913-00-2-R1-023	8/6/2019	-	-	-	-	-	-	-	n/a	N/A
6914-09-001	8/6/2019	-	-	-	-	-	-	-	n/a	N/A
6900-22-1-L1-010	8/6/2019	0.09 mg/l	0.3 mg/l	187 uS/cm	0.09 ppt	E. coli <10 MPN/100ml	<0.05 mg/l	19.3 C	n/a	Will raise priority category from low to high for potential catchment investigation
6900-22-1-L1-009	8/6/2019	0.13 mg/l	Not detected	230 uS/cm	0.11 ppt	E. coli <10 MPN/100ml	<0.05 mg/l	18.9 C	n/a	N/A
6900-22-1-L1-011	8/6/2019	-	-	-	-	-	-	-	n/a	N/A
6913-02-1-013MH	8/27/2019	-	-	-	-	-	-	-	n/a	N/A
6913-02-1-021	8/27/2019	0.25 mg/l	Not detected	228 uS/cm	0.12 ppt	E. coli 41 MPN/100ml	<0.05 mg/l	18.47 C	n/a	N/A
6913-02-1-022	8/27/2019	0.07 mg/l	Not detected	239 uS/cm	0.13 ppt	E. coli 41 MPN/100ml	<0.05 mg/l	18.7 C	n/a	N/A
6913-02-1-020	8/27/2019	0.20 mg/l	Not detected	252 uS/cm	0.13 ppt	E. coli 583 MPN/100ml	<0.05 mg/l	20.42 C	n/a	Will raise priority category from low to high for potential catchment investigation
6913-02-1-012	8/27/2019	0.29 mg/l	0.3 mg/l	231 uS/cm	0.12 ppt	E. coli <10 MPN/100ml	<0.05 mg/l	18.94 C	n/a	Will raise priority category from low to high for potential catchment investigation
6913-02-1-018	8/27/2019	<0.05 mg/l	0.2 mg/l	382 uS/cm	0.21 ppt	E. coli 213 MPN/100ml	<0.05 mg/l	18.95 C	n/a	Will raise priority category from low to high for potential catchment investigation
6913-00-2-R2-001	8/27/2019	0.10 mg/l	0.1 mg/l	431 uS/cm	0.23 ppt	E. coli 31 MPN/100ml	<0.05 mg/l	19.29 C	n/a	Will raise priority category from low to high for potential catchment investigation
6913-01-1-003	8/27/2019	-	-	-	-	-	-	-	n/a	N/A
6913-01-1-005	8/27/2019	-	-	-	-	-	-	-	n/a	N/A
6913-00-2-R1-036	8/27/2019	-	-	-	-	-	-	-	n/a	N/A
6913-00-2-R2-011	8/27/2019	-	-	-	-	-	-	-	n/a	N/A
6913-00-2-R2-005	8/27/2019	-	-	-	-	-	-	-	n/a	N/A

6913-00-2-R2-006	8/27/2019	-	-	-	-	-	-	-	n/a	N/A
6913-02-1-009	8/27/2019	-	-	-	-	-	-	-	n/a	N/A
6913-02-1-011	8/27/2019	-	-	-	-	-	-	-	n/a	N/A
6913-03-1-014	9/10/2019	-	-	-	-	-	-	-	n/a	N/A
6913-03-1-L1-003	9/10/2019	-	-	-	-	-	-	-	n/a	N/A
6913-03-1-013	9/10/2019	-	-	-	-	-	-	-	n/a	N/A
6913-02-1-019	9/10/2019	-	-	-	-	-	-	-	n/a	N/A
6913-02-1-015	9/10/2019	-	-	-	-	-	-	-	n/a	N/A
6913-03-1-002a	9/10/2019	-	-	-	-	-	-	-	n/a	N/A
6913-03-1-001a	9/10/2019	0.10 mg/l	Not detected	277.6 uS/cm	0.09 ppt	E. coli 288 MPN/100ml	<0.05 mg/l	17.6 C	n/a	N/A
6913-03-1-003	9/10/2019	0.05 mg/l	0.1 mg/l	435.3 uS/cm	0.11 ppt	E. coli <10 MPN/100ml	<0.05 mg/l	18 C	n/a	Will raise priority category from low to high for potential catchment investigation
6913-02-1-023	9/10/2019	-	-	-	-	-	-	-	n/a	N/A
6900-24-1-004	9/10/2019	0.07 mg/l	Not detected	338.3 uS/cm	0.1 ppt	E. coli <10 MPN/100ml	0.07 mg/l	19.4 C	n/a	N/A
6916-00-3-L4-005	9/10/2019	0.09 mg/l	0.1 mg/l	400.6 uS/cm	0.14 ppt	E. coli 52 MPN/100ml	0.10 mg/l	18.2 C	n/a	Will raise priority category from low to high for potential catchment investigation
6916-00-3-L4-002	9/10/2019	-	-	-	-	-	-	-	n/a	N/A
6916-00-3-L4-003	9/10/2019	0.12 mg/l	Not detected	401.3 uS/cm	0.1 ppt	E. coli 10 MPN/100ml	0.07 mg/l	19.6 C	n/a	N/A
6916-11-1-002	9/26/2019	-	-	-	-	-	-	-	n/a	N/A
6916-11-1-L1-003	9/26/2019	0.14 mg/l	Not detected	232 uS/cm	0.11 ppt	E. coli 17300 MPN/100ml	<0.05 mg/l	16.39 C	n/a	Will raise priority category from low to high for potential catchment investigation
6916-11-1-L1-010 MH	9/26/2019	0.16 mg/l	0.1 mg/l	202 uS/cm	0.1 ppt	E. coli 41 MPN/100ml	<0.05 mg/l	16.84 C	n/a	Will raise priority category from low to high for potential catchment investigation

6916-11-1-L1-011 MH	9/26/2019	0.05 mg/l	Not detected	271 uS/cm	0.13 ppt	E. coli 10 MPN/100ml	<0.05 mg/l	19.84 C	n/a	N/A
6916-10-1-003	9/26/2019	-	-	-	-	-	-	-	n/a	N/A
6916-10-1-002	9/26/2019	-	-	-	-	-	-	-	n/a	N/A
6916-10-1-004	9/26/2019	-	-	-	-	-	-	-	n/a	N/A
6916-10-1-005	9/26/2019	-	-	-	-	-	-	-	n/a	N/A
6916-10-1-001	9/26/2019	-	-	-	-	-	-	-	n/a	N/A
6916-10-1-L1-005	9/26/2019	-	-	-	-	-	-	-	n/a	N/A
6916-10-1-L1-001	9/26/2019	0.10 mg/l	0.1 mg/l	578 uS/cm	0.28 ppt	E. coli <10 MPN/100ml	<0.05 mg/l	19.2 C	n/a	Will raise priority category from low to high for potential catchment investigation
6916-10-1-L1-003	9/26/2019	-	-	-	-	-	-	-	n/a	N/A
										N/A

*When the City performed GPS field locating of “ends of pipes” during the previous permit period, information such as observable flow, appearance, smell, in addition to other outfall characteristics/dimensions, was recorded. Historical weather data was verified that it was dry in the 24-hour period prior to this screening. Outfalls with no observable flow and no evidence of an illicit discharge, were considered to have had dry weather outfall screening and the date was recorded in current outfall inventory/sampling tables.

**The sample from 6914-11-1-02 for E. coli analysis was in an unpreserved jar. Since the sample had chlorine detected, the E. coli result may not be accurate. Outfall will be scheduled for follow-up investigation.

+Potential inaccuracies of 2019 chlorine data may be present due to field kit equipment malfunction/issues

2.2 Wet weather sample and inspection data

Provide sample data for outfalls and key junction manholes of any catchment area with at least one System Vulnerability Factor.

Outfall / Interconnection ID	Sample date	Ammonia	Chlorine	Conductivity	Salinity	E. coli or Enterococcus	Surfactants	Water Temp	Pollutant of concern
None at this time									

3. Catchment Investigation data (Appendix B (A)(7)(e) / page 9)

3.1 System Vulnerability Factor Summary

For those catchments being investigated for illicit discharges (i.e. categorized as high priority, low priority, or problem) document the presence or absence of System Vulnerability Factors (SVF). If present, report which SVF's were identified. An example is provided below.

Outfall ID	Receiving Water	System Vulnerability Factors
NA		

Where SVFs are:

1. History of SSOs, including, but not limited to, those resulting from wet weather, high water table, or fat/oil/grease blockages.
2. Sewer pump/lift stations, siphons, or known sanitary sewer restrictions where power/equipment failures or blockages could readily result in SSOs.
3. Inadequate sanitary sewer level of service (LOS) resulting in regular surcharging, customer back-ups, or frequent customer complaints.
4. Common or twin-invert manholes serving storm and sanitary sewer alignments.
5. Common trench construction serving both storm and sanitary sewer alignments.
6. Crossings of storm and sanitary sewer alignments.
7. Sanitary sewer alignments known or suspected to have been constructed with an underdrain system;
8. Sanitary sewer infrastructure defects such as leaking service laterals, cracked, broken, or offset sanitary infrastructure, directly piped connections between storm drain and sanitary sewer infrastructure, or other vulnerability factors identified through Inflow/Infiltration Analyses, Sanitary Sewer Evaluation Surveys, or other infrastructure investigations.
9. Areas formerly served by combined sewer systems.
10. Any sanitary sewer and storm drain infrastructure greater than 40 years old in medium and densely developed areas.
11. Widespread code-required septic system upgrades required at property transfers (indicative of inadequate soils, water table separation, or other physical constraints of the area rather than poor owner maintenance).
12. History of multiple local health department or sanitarian actions addressing widespread septic system failures (indicative of inadequate soils, water table separation, or other physical constraints of the area rather than poor owner maintenance).

3.2 Key junction manhole dry weather screening and sampling data

Key Junction Manhole ID	Screening / Sample date	Visual/ olfactory evidence of illicit discharge	Ammonia	Chlorine	Surfactants
NA					

3.3 Wet weather investigation outfall sampling data

Outfall ID	Sample date	Ammonia	Chlorine	Surfactants
NA				

3.4 Data for each illicit discharge source confirmed through the catchment investigation procedure

Discharge location	Source location	Discharge description	Method of discovery	Date of discovery	Date of elimination	Mitigation or enforcement action	Estimated volume of flow removed
NA							

Part IV: Certification

“I have personally examined and am familiar with the information submitted in this document and all attachments thereto, and I certify that, based on reasonable investigation, including my inquiry of those individuals responsible for obtaining the information, the submitted information is true, accurate and complete to the best of my knowledge and belief. I understand that a false statement made in this document or its attachments may be punishable as a criminal offense, in accordance with Section 22a-6 of the Connecticut General Statutes, pursuant to Section 53a-157b of the Connecticut General Statutes, and in accordance with any other applicable statute.”

Chief Elected Official or Principal Executive Officer	Document Prepared by
Print name:	Print name:
Signature / Date:	Signature / Date:

DRAFT